
210538



February 16-22, 1997

OXFORD ENVIRONMENTAL, INC.

43 Route 46 East, Pine Brook, NJ 07058 · Phone [201] 244-0600 · Fax (201) 244-0722



Fax Transmittal

To:	Evic Wilson	From:	very Bayer	
Соптрат	* US EPA-Reg	in I o	, KFORD ENVIRONMEI	NTAL, INC.
Faxc	908 - 906 - 618	≥ Pages:	6	
Phone:	908 906 - 699	Date:	5-8-97	
Re:	Cornell Bubiller	- CC:		
_	ont For Review Pl		Please Réply 🗆 Pi	ease Recycle
• Com	menti We ave	shopping for	- unterrals-	Should
	i de la la companya de la Lacia de la Caracia de la Car			٠, ٠
neers Wee	sediment co	atrols,	- 	
iii) E				
TITLE				


If you have received this fax in error, please notify the sender at 1-800-377-8218.

CONFIDENTIALITY NOTICE:

The Information contained herein is privileged and confidential and is intended for the sole use of the recipient.

Any unauthorized copying, distribution or dissemination of information, in whole or in part, is strictly prohibited.

Violators of this notice will be subject to legal action under the fullest extent of the law.



MAP KEY


SOIL SAMPLE


SURFACE WATER/SEDEMENT SAMPLE

CORNELL DURILIER ELECTRONICS

PROP. IMMEDIATE A CTIONS RE SEDIMENT & PROP. IMMEDIATE

5/8/97





STANDARD FOR SEDIMENT BARRIER

Definition

A temporary barrier installed across or at the toe of a slope.

Purpose

The purpose of a sediment barrier is to intercept and detain small amounts of sediment from unprotected areas of limited extent.

Conditions Where Practice Applies

The sediment barrier is used where:

- 1. No other practice is feasible,
- 2. There is no concentration of water in a channel or other drainageway above the barrier, and
- 3. Erosion would occur in the form of sheet and rill erosion.

Design Criteria

- A. All types of sediment barriers:
 - 1. Contributing drainage area is less than 1 acre and the length of slope above the barrier is less than 150 feet.
 - 2. The slope of the contributing drainage area for at least 30 feet adjacent to the barrier shall not exceed 5%.
 - 3. The barrier shall be constructed so water cannot bypass the barrier around the ends.
 - 4. Inspection shall be frequent and repair or replacement shall be made promptly as needed.
 - 5. The barrier shall be removed when it has served its usefulness so as not to block or impede storm flow or drainage.
- 8. Requirements for bale barrier (e.g., straw, hay, or other acceptable vegetative material):
 - 1. All bales shall be securely fled and staked on the contour. See Figure 4.13-1 for details.
 - 2. Sales shall be placed in a row with ends tightly abutting the edjacent bales.
 - 3. Each bale shall be embedded in the soil a minimum of 4 inches.
 - 4. Bales shall be securely anchored in place by two stakes or re-bars driven through each bale. The first stake in each bale shall be driven toward previously laid bale to force bales together.
- C. Requirements for silt fence:
 - 1. Fence posts shall be spaced 8 feet center-to-center or closer. They shall extend at least 2 feet into the ground. They shall extend at least 2 feet above ground.
 - 2. A metal fence with 6 Inch or smaller openings and at least 2 feet high may be utilized, fastened to the fence posts.
 - 3. A filter fabric, recommended for such use by the manufacturer, shall be buried at least 6 inches deep in the ground. The filter fabric shall extend at least 2 feet above the ground. Filter fabric may be fastened in place by stake or other accepted means as specified by the district office.
- D. Requirements for stone barrier:
 - 1. The stone shall be piled to a natural angle of repose with a height of at least 2 feet.
 - 2. The stone shall meet ASTM C-33 size No. 2 or 3.

Sediment Barrier

STANDARD FOR STORM SEWER INLET PROYECTION

Definition

A temporary barrier and settling facility installed at a storm sewer inlet.

Purpose

The purpose of storm sewer injet protection is to intercept and retain sediment, thus preventing the entrance of sediment into the storm sewer system.

Conditions Where Practice Applies

- 1. Contributing drainage area is 3 acres or less.
- 2. A storm sewer or the outlet channel of a storm sewer needs protection from sediment.
- 3. Traffic will not destroy or cause constant maintenance of the storm sever inlet protection.
- 4. A traffic hazard will not be created.

Design Criteria

- A. General All types of storm sewer inlet protection:
 - 1. Must slow the storm water, provide the coarse sediment particles a chance to settle, and provide an area to retain the particles that have settled; or
 - 2. Must prevent the storm water from entering the catch basin injet.

The following sections provide three methods. Other methods that accomplish the purpose of storm sewer injet protection may be used if approved by the Soil Conservation District.

inspections shall be frequent. Maintenance, repair, and replacement shall be made promptly as needed.

The barrier shall be removed when the area draining toward the inlet has been stabilized.

- B. Blocked Injet Catch basin injets may be blocked, until the area draining toward the catch basin is permanently protected from erosion, when:
 - 1. The material used to block the inlet is prevented from floating or being carried into the inlet; and
 - 2. an erosion or a flooding problem is not caused by blocking the inlet.
- C. Protected Inlet:
 - 1. The perimeter length of the barrier shall be at least four times the perimeter length of the storm sewer injet. The top of the barrier shall be level and uniform for at least this length.
 - 2. The barrier shall encircle the inlet.
 - 3. If bales (straw, hay or other acceptable vegetative materials) are used for the barrier, they shall be staked down in accordance with the sediment barrier standard. Where staking is not practical, they shall be tied together to prevent movement or openings in the barrier.
 - 4. If gravel is used for the barrier, it shall be piled at least 1 1/2 feet high to its natural angle of repose. The gravel shall meet size no. 2 or 3 in ASTM C-33.
- D. Inlet with Sediment Trap:
 - 1. A screen is placed completely over the inlet.
 - A sturdy protective frame is placed around the inlet and filled with ASTM C-33 size no. 2 or 3 stone.

Storm Sewer Inlet Protection

4.16.1

Revised April 1987